

Certificate of Compliance

Certificate Number(s):

UL-US-26101247-0

Report Reference:

E551682-20260114

Issue Date:

2026-01-16

Issued to:

**TM TECHNOLOGIE Sp. z o.o.
Morawica 355, Morawica, 32-084, PL**

This certificate confirms that representative samples of:

FTER - Emergency Lighting Equipment and Systems Certified to EN Standards

See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.

**EN 50171:2021
EN 62034:2012**

Additional Information:

See UL Product iQ® at <https://iq.ulprospector.com> for additional information.

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



David Piecuch
UL Mark Certification Program Manager



Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.

CERTIFICATE OF COMPLIANCE

Certificate number(s): UL-US-26101247-0
Report reference: E551682-20260114
Issue Date: 2026-01-16

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Central Battery Emergency Lighting Systems

Model(s): TM-CB M SUB PRx *TM-CB M SUB PRx*

Where:

x = Maximum number of Circuits (may be "12" or "20")

Model(s): TM-CB Mx/y-zw-a *TM-CB Mx/y-zw-a*

Where:

x = Version of Station (Housing) (may be "1" or "2" or "3" or "4" or "5" or "6" or "7" or "8" or "9" or "10").

y = Battery Capacity in Ah (may be "5" or "7" or "12" or "18" or "20" or "26" or "28" or "33" or "40" or "45" or "55" or "65" or "75" or "80" or "90" or "100" or "120" or "134" or "150").

z = Model of Back Plane (may be "0" or "1" or "2").

w = Maximum number of Circuits in the Station (may be "06" or "12" or "20").

a = Maximum number of Sub-Distribution Boards (may be "00" or "01" or "04" or "07" or "15").

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.

